



FLOYD COUNTY HIGH SCHOOL
"Home of the Buffaloes"



721 Baker Street S.W.
Floyd, VA 24091-0199
Phone (540) 745-9450
Fax (540) 745-9481

Barry A. Hollandsworth, Principal
G. Tony Deibler, Assistant Principal
Chris Hewitt, Vocational Director/Assistant Principal

January 29, 2009

To the Parents of Floyd County High School Students:

Today, a pressure valve malfunctioned in the boiler system which transports heated water throughout the building. Due to the failure of the valve, fresh water was contaminated. We are confident all contaminated water was restricted to just one restroom and the kitchen.

Our response to this contamination was as follows:

- Immediately turned off defective valve.
- All food prepared in the cafeteria, requiring any water, was thrown out. Additionally, disposable plates and utensils were used in the cafeteria during lunches.
- All water fountains and sinks in the high school were shut off.
- Bottled water was provided for students and staff for drinking purposes. Hand sanitizers were available for student and staff use.
- The department of health was contacted and we are following their instructions to flush out all contaminated lines. Water will be tested before being turned back on for public use.
- We will continue to supply bottled water and hand sanitizers until this problem has been resolved.

Should you have any questions please call us, 745-9450.

Sincerely,

Barry Hollandsworth, Principal

An Equal Opportunity Employer

The Floyd County School Board does not discriminate on the basis of race, color, religion, national origin, political affiliation, gender, age, marital status, or disability in its educational programs, admission to any program, or employment.